



505 - 6th Street, Suite 200  
New Westminster, BC V3L 0E1

Toll Free: 1-866-566-SAFE  
Fax: (778) 396 - 2064  
www.safetyauthority.ca

ALBERTA BOILERS SAFETY ASSOCIATION  
9410 20 AVENUE NW  
EDMONTON AB T6N 0A4

**Date:** July 6, 2016  
**Account #:** 34986  
**Journal #:** 65875  
**Our File #:** 5597819

**Attn:** CYNTHIA FORMANIUK

**Re:** Application for Design Registration

The design, as detailed in your, ABSA Tracking No: 2016-02224, for a Fitting is accepted for registration as follows:

**Registered To:** PENTAIR VALVES AND CONTROLS  
US LP **CRN:** 0F00927.921

**MAWT:** 700 deg F

**MAWP:** 3000 psig

**Drawing #:** Company Name Change

**Conditions Of Registration:**

Registration of name change for Boiler Trim Port Gages.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

**Reviewer's Notes:**

As required by CSA B51 4.2.1, this registration expires on May 21, 2020. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@safetyauthority.ca  
Design Administration

**cc:**